

Site HOTO Report — SYL_X0613

Project Tiger · Dhaly Infratech → Alliance Computers Limited · Generated 31-Aug-2026 21:00 BD time

SITE & HANDOVER DETAILS

SITE CODE	SYL_X0613	ZONE	Sylhet
HOTO DATE	2026-08-31	DISTRICT	Sunamganj
HANDOVER ORG	Dhali	TAKEOVER ORG	Alliance Computers Limited
HANDOVER PERSON	Md. Eidris ali	TAKEOVER PERSON	Md. Ismail hossain
HANDOVER PHONE	01750537433	TAKEOVER PHONE	01847426958
INSPECTED BY	ismail siraji	SECURITY GUARD	Yes

GENERATOR INFORMATION

DG BRAND	Fg wilson	GENSET ASSET NO.	N/A
CAPACITY (KVA)	22	TYPE	Can
FUEL TANK CAPACITY	2000	PRESENT RH	4345.3
FUEL (NO WATER)	134 L	FUEL (TOTAL)	149 L
WATER AMOUNT	15 L	FUEL AMOUNT (WORD)	One hundred threty four
DG PRESENT STATUS	OK	GENSET ON ALARM	OK
BATTERY BRAND	Hamko	BATTERY SERIAL	P033wnd010086
BATTERY AH	100	ENGINE SERIAL	GV51792
ATS BRAND	Local	ATS MODE	Auto
RH METER TYPE	Digital from controller	LAST SERVICE DATE	2026-05-23
KEY STATUS — BTS	LOCAL	KEY STATUS — DG ROOM	ROOM NOT available DG canopy husband lock Local
ACTIVE DG	1	CONNECTED FUEL TANKS	1
FAULTY/DISCONNECTED DG	—	FAULTY/DISCONNECTED TANKS	—

CONNECTED GENERATOR CHECKLIST & READINGS

ITEM	VALUE	ITEM	VALUE
Earth Connection OK	Yes	Load Current (A)	11
Frequency (Hz)	50.2	Phase	3 Phase
Output	Ac voltage 418	Voltage L1-L2	418
Voltage L2-L3	418	Voltage L3-L1	417
Voltage L1-N	242	Voltage L2-N	242
Voltage L3-N	241	Current Line 1	11
Current Line 2	11	Current Line 3	11
N-G	07.8	Engine Brand	Parkings

Controller Status	OK	Black Smoke Status	OK
DG Battery Charger	OK	ATS Physical & Functional Status	OK
DG Automation per BL Standard	OK	Fuel Preserved at Safe Location	OK
Exhaust Fan / Ventilation Sufficient	OK	Sufficient Water in Radiator & Battery	OK
DG Radiator Condition	OK	DG Battery Condition	OK
Runs in Auto & Manual Mode	OK	GENSET ON Alarm Functioning	OK
Lub Oil Status	NOK	RH Meter Working Properly	OK
No Parts Missing	OK		

SNAGS FOUND (0)

No snags logged for this visit.

DEFICIENCIES & SAFETY REMARKS

DG MAJOR DEFICIENCIES	Lub oil shottese
SAFETY REMARKS	—
GENERAL REMARKS	—

SITE PHOTOS

 Site / Nameplate	 DG RH / Meter	 Fuel Gauge
---	--	---

Md. Eidris ali Handed Over By · Dhali 01750537433 Date: _____	Md. Ismail hossain Taken Over By · Alliance Computers Limited 01847426958 Date: _____	BL Concern · Name / Signature Date: _____
---	--	--