

## Site HOTO Report — SYL\_X0043

Project Tiger · Dhaly Infratech → Alliance Computers Limited · Generated 31-Aug-2026 21:00 BD time

### SITE & HANDOVER DETAILS

|                 |                |                 |                            |
|-----------------|----------------|-----------------|----------------------------|
| SITE CODE       | SYL_X0043      | ZONE            | Sylhet                     |
| HOTO DATE       | 2026-08-31     | DISTRICT        | Sunamganj                  |
| HANDOVER ORG    | Dhali          | TAKEOVER ORG    | Alliance Computers Limited |
| HANDOVER PERSON | Md. Eidris Ali | TAKEOVER PERSON | Md. Ismail hossain         |
| HANDOVER PHONE  | 01750537433    | TAKEOVER PHONE  | 01847426858                |
| INSPECTED BY    | ismail siraji  | SECURITY GUARD  | No                         |

### GENERATOR INFORMATION

|                        |                         |                           |                         |
|------------------------|-------------------------|---------------------------|-------------------------|
| DG BRAND               | Fg wilson               | GENSET ASSET NO.          | 20060052IRD             |
| CAPACITY (KVA)         | 22                      | TYPE                      | Can                     |
| FUEL TANK CAPACITY     | 2000                    | PRESENT RH                | 442.8                   |
| FUEL (NO WATER)        | 186 L                   | FUEL (TOTAL)              | 149 L                   |
| WATER AMOUNT           | 37 L                    | FUEL AMOUNT (WORD)        | One hundred fourty nine |
| DG PRESENT STATUS      | OK                      | GENSET ON ALARM           | OK                      |
| BATTERY BRAND          | Hamko                   | BATTERY SERIAL            | P033WECK0207            |
| BATTERY AH             | 100                     | ENGINE SERIAL             | HP51109U981641P         |
| ATS BRAND              | Local                   | ATS MODE                  | Auto                    |
| RH METER TYPE          | Digital from controller | LAST SERVICE DATE         | 2026-05-24              |
| KEY STATUS — BTS       | LOCAL                   | KEY STATUS — DG ROOM      | LOCAL                   |
| ACTIVE DG              | 1                       | CONNECTED FUEL TANKS      | 1                       |
| FAULTY/DISCONNECTED DG | 00                      | FAULTY/DISCONNECTED TANKS | 00                      |

### CONNECTED GENERATOR CHECKLIST & READINGS

| ITEM                | VALUE | ITEM             | VALUE    |
|---------------------|-------|------------------|----------|
| Earth Connection OK | Yes   | Load Current (A) | 24       |
| Frequency (Hz)      | 50    | Phase            | 3 Phase  |
| Output              | 400   | Voltage L1-L2    | 402      |
| Voltage L2-L3       | 400   | Voltage L3-L1    | 401      |
| Voltage L1-N        | 232   | Voltage L2-N     | 232      |
| Voltage L3-N        | 230   | Current Line 1   | 8        |
| Current Line 2      | 8     | Current Line 3   | 8        |
| N-G                 | 3.354 | Engine Brand     | Parkings |

|                                      |     |                                        |    |
|--------------------------------------|-----|----------------------------------------|----|
| Controller Status                    | OK  | Black Smoke Status                     | OK |
| DG Battery Charger                   | OK  | ATS Physical & Functional Status       | OK |
| DG Automation per BL Standard        | OK  | Fuel Preserved at Safe Location        | OK |
| Exhaust Fan / Ventilation Sufficient | OK  | Sufficient Water in Radiator & Battery | OK |
| DG Radiator Condition                | OK  | DG Battery Condition                   | OK |
| Runs in Auto & Manual Mode           | OK  | GENSET ON Alarm Functioning            | OK |
| Lub Oil Status                       | NOK | RH Meter Working Properly              | OK |
| No Parts Missing                     | OK  |                                        |    |

## SNAGS FOUND (2)

| SNAG # | CATEGORY             | COMPONENT     | STATUS | OBSERVATIONS                                                                           | ACTION |
|--------|----------------------|---------------|--------|----------------------------------------------------------------------------------------|--------|
| S-003  | DG - Battery/Starter | (unspecified) | Faulty | 1) Dg fan belt loss, 2)charging dynamo poparly not setting 3) engine loop oil shortest | Open   |
| S-004  | DG - Battery/Starter | (unspecified) | Faulty | 1) Dg fan belt loss, 2)charging dynamo poparly not setting 3) engine loop oil shortest | Open   |

## DEFICIENCIES & SAFETY REMARKS

|                       |                                                                                        |
|-----------------------|----------------------------------------------------------------------------------------|
| DG MAJOR DEFICIENCIES | —                                                                                      |
| SAFETY REMARKS        | —                                                                                      |
| GENERAL REMARKS       | 1) Dg fan belt loss, 2)charging dynamo poparly not setting 3) engine loop oil shortest |

## SITE PHOTOS

|                                                                                     |                                                                                     |                                                                                       |
|-------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------|
|  |  |  |
| Site / Nameplate                                                                    | DG RH / Meter                                                                       | Fuel Gauge                                                                            |

### Md. Eidris Ali

Handed Over By · Dhali  
01750537433

Date: \_\_\_\_\_

### Md. Ismail hossain

Taken Over By · Alliance Computers  
Limited  
01847426858

Date: \_\_\_\_\_

BL Concern · Name / Signature

Date: \_\_\_\_\_